

Where Does My Water Come From?

The Department of Public Utilities obtains its raw water from the North Fork Edisto River. The high quality and abundant quantity provides for future community and economic development. Our water treatment plant processes an average of 8 million gallons per day (MGD) and has the capability to treat 30 MGD.



A Source Water Assessment was performed by SCDHEC and results are available by visiting the web site www.scdhec.net/eqc/water.html/srcwtr.html or by calling the Water Division at 803-268-4404.



SC Section
American Water Works
Association

Department of Public Utilities

City of Orangeburg
PO Box 1057
Orangeburg, South Carolina 29116


O. Thomas Miller, Jr., Manager
Eric Odom, Water Division Director

How To Contact Us:

Please call the Water Division at
Phone: 803-268-4404 or Fax: 803-531-3803
or visit our website at: www.orbgdpu.com

The water supplied to you by YOUR
Department of Public Utilities meets and
exceeds all drinking water requirements.

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien, favor de llamar a Servicio del Cliente at 268-4186.



Your Utility Source
"Over 100 Years"

*Our Water Meets
and Exceeds All
Drinking Water
Requirements!*

2013 WATER QUALITY REPORT



Your Utility Source

Availability of Monitoring Data for Unregulated Contaminants for Orangeburg DPU

Our water system has sampled for a series of unregulated contaminants. Unregulated contaminants are those that don't yet have a drinking water standard set by the Environmental Protection Agency. The purpose of monitoring for these contaminants is to help EPA decide whether the contaminants should have a standard. As our customers, you have a right to know that these data are available. If you are interested in examining the results, please contact Mr. Odom at 803-268-4404.

Contaminants that may be present in Source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, or wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally occurring, may result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and may also come from gas stations, urban stormwater runoff and septic systems.

Radioactive contaminants, which can be naturally occurring or may be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Lead in drinking water... get in the know!

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing.

Orangeburg DPU is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking.

If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, treatment methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (800-426-4791) or at <http://www.epa.gov/safewater/lead>.

Why are there contaminants in the water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate the water poses a health risk. The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material, and can pick up substances resulting from the presence of animals or human activity. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

Special Concerns

Some people may be more vulnerable to the contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS, or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care provider. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).

Since 1993, the Department of Public Utilities has sampled at least annually for giardia and cryptosporidium using current analytical methods. These organisms have never been detected in our finished water.

2013 Water Quality Data

	Substance	Number of Tests	MCL	MCLG	Detected Level	Range	Major Sources	Meets EPA Standards
Inorganics	Fluoride (as tested by DHEC) (PPM)	1	4	4	0.73	0.73	Water additive which promotes strong teeth; Erosion of natural deposits; Discharge from fertilizer and aluminum factories.	Yes
	Fluoride (as tested by our DHEC certified laboratory) (PPM)	730	4	4	0.69	0.37 - 0.75	Water additive which promotes strong teeth; Erosion of natural deposits; Discharge from fertilizer and aluminum factories.	Yes
	Nitrate (PPM)	1	10	10	0.27	0.27	Run-off from fertilizer use; Leaching from septic tank sewage; Erosion from natural deposits.	Yes
Volatile Organics	Total Trihalomethanes (PPB)	4	80	N/A	RAA= 23	16.9 - 28.9	By-product of drinking water disinfection.	Yes
	Haloacetic Acids (PPB)	4	60	N/A	RAA= 48	30.2 - 64.4	By-product of drinking water disinfection.	Yes
Micro-biological	Total Coliform (P/A)	1612		0	1.45%	0.0 - 4.90%	Naturally present in the environment	Yes
	Turbidity (NTU)	2920		0	0.07 100%	0.05 - 0.11 100%	Soil runoff.	Yes
Disinfection By-Products	Residual Chlorine (PPM)	1612	MRDL = 4	MRDL = 4	RAA=2.6	1.7 - 2.6	Water additive used to control microbes.	Yes
	Total Organic Carbon (PPM)	12	TT	Required % removal 47.1%	Actual % removal 66.2%	Actual % removal range 56.8 - 77.4%	Naturally present in the environment.	Yes

2013 Lead and Copper Data

Substance	Number of Tests	Action Level	MCLG	90th Percentile	Range	Number of Sites Above Action Level	Major Sources	Meets EPA Standards
Lead* (PPB)	30	AL = 15	0	0.0	ND - 3	0	Corrosion of household plumbing systems; Erosion of natural deposits.	Yes
Copper* (PPM)	30	AL = 1.3	0	0.067	ND - 0.166	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives.	Yes

* Sampled July 2011. Scheduled to be collected again Summer 2014.

Key to Tables

- MCL = Maximum Contaminant Level
- MCLG = Maximum Contaminant Level Goal
- MRDL = Maximum Residual Disinfectant Level
- N/A = Not Applicable
- ND = Not Detected
- NTU = Nephelometric Turbidity Unit
- P/A = Presence / Absence
- PPB = Micrograms per liter or parts per billion or one ounce in 7,350,000 gallons of water
- PPM = Milligrams per liter or parts per million or one ounce in 7,350 gallons of water
- RAA = Running Annual Average

How Do I Read This Table?

The table contains the name of each substance, the highest level allowed by regulation (MCL), the ideal goals for public health (MCLG), the amount detected, the usual sources of such substances, and a key to units of measurement.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Maximum Residual Disinfectant Level (MRDL): The highest level of disinfectant allowed in the drinking water. There is compelling evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLG's do not reflect the benefits of the use of disinfectants to control microbial contaminants.

2013 Unregulated Contaminant Monitoring (UCMR3)

Substance	Finished Water			Distribution Water		
	Average	Low	High	Average	Low	High
Hexavalent Chromium (dissolved) (PPB)	0.19	0.14	0.24	0.12	0.11	0.12
Total Chromium (PPB)	0.28	0.18	0.38	0.20	0.13	0.27
Strontium (PPB)	21	14	28	23.5	17	30
Vanadium (PPB)	0.53	0.16	0.89	0.44	0.40	0.48
Chlorate (PPB)	ND	ND	ND	110	ND	220